

Summary Report

www.bsria.co.uk

Summary Report 54763/7

Issue No: 1

Date of issue: 10 October 2018

This Summary Report confirms that BSRIA Ltd has tested a sample of the product described below in accordance with the test methods contained within EN 13030 : 2001 and have determined the item met the detailed classification shown on pages 3 to 6. For further details of the test item see Page 2 of this Summary Report.

Manufacturer/Agent	N.V. Renson Projects IZ 2 Vijverdam Maalbeekstraat 6 B-8790 Waregem
Product	411
Test location	BSRIA Old Bracknell West Bracknell Berkshire RG12 7AH
Date of test	29 December 2010 and 11 February 2011
Date of issue	9 October 2018
Test engineer	A Freeth
Quality approved	Mark Roper Principal Test Engineer

This Summary Report must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

This summary report supersedes certificate 54763/7. This up-date was carried out under BSRIA contract reference 61223.

TEST INFORMATION

Contract	54763
Date	December 2010
Manufacturer	N.V. Renson Projects
Louvre Model	411
Material	Aluminium
Painted	No
Blade Height	1015 mm
Blade Width	1000 mm
Blade Depth	19 mm
Frame Depth	28 mm
No. of Blades	30
Blade Pitch	33 mm
Blade Angle	45 degrees
No. of Banks	1
Guard Type	Insect/None
Guard Spacing	7 mm
Side Channels	None
Water Drip Tray	Yes
Blade Orientation	Horizontal


Front view of louvre

COEFFICIENT OF ENTRY (with mesh)

MANUFACTURER Renson Date 29/12/2010
 MODEL 411 (with mesh) Contract 54763

air temperature 11.6 °C louvre height 1015 mm
 barometer 1016 mbar louvre width 1000 mm
 air density 1.238 kg/m³ louvre area 1.015 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s	
210.0	3.76	3.820	18.695	0.204
193.0	3.61	3.666	17.922	0.205
171.0	3.40	3.451	16.870	0.205
156.0	3.26	3.308	16.113	0.205
138.0	3.05	3.098	15.155	0.204
119.0	2.85	2.889	14.073	0.205
102.0	2.65	2.690	13.029	0.206
84.0	2.42	2.456	11.824	0.208
58.0	2.02	2.047	9.825	0.208
28.0	1.42	1.445	6.826	0.212
mean C _e				0.206
Class				3




COEFFICIENT OF DISCHARGE (with mesh)

MANUFACTURER Renson Date 29/12/2010
 MODEL 411 Reversed (with mesh) Contract 54763

air temperature 10.5 °C louvre height 1015 mm
 barometer 1016 mbar louvre width 1000 mm
 air density 1.243 kg/m³ louvre area 1.015 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient Cd
	m/s	test m ³ /s	theoretical m ³ /s	
221.0	3.75	3.804	19.141	0.199
203.0	3.57	3.627	18.345	0.198
186.0	3.43	3.478	17.560	0.198
168.0	3.26	3.305	16.689	0.198
148.0	3.05	3.096	15.664	0.198
128.0	2.83	2.871	14.567	0.197
109.0	2.62	2.663	13.443	0.198
89.0	2.37	2.403	12.147	0.198
61.0	1.94	1.972	10.056	0.196
31.0	1.40	1.417	7.169	0.198
mean Cd				0.198
Class				4




COEFFICIENT OF ENTRY (no mesh)

MANUFACTURER Renson Date 29/12/2010
 MODEL 411 (no mesh) Contract 54763

air temperature 14 °C louvre height 1015 mm
 barometer 1007 mbar louvre width 1000 mm
 air density 1.217 kg/m³ louvre area 1.015 m²

louvre pd Pascals	louvre face velocity		air flow rate		coefficient C _e
	m/s		test m ³ /s	theoretical m ³ /s	
201.0	3.77		3.828	18.449	0.208
176.8	3.55		3.602	17.302	0.208
158.5	3.36		3.411	16.383	0.208
134.0	3.10		3.148	15.063	0.209
117.0	2.90		2.939	14.075	0.209
97.0	2.64		2.683	12.816	0.209
75.5	2.34		2.379	11.307	0.210
57.5	2.06		2.090	9.867	0.212
39.2	1.69		1.718	8.147	0.211
19.1	1.19		1.209	5.687	0.213
mean C _e					0.210
Class					3




COEFFICIENT OF DISCHARGE (no mesh)

MANUFACTURER Renson
 MODEL 411 Reversed (no mesh)

Date 29/12/2010
 Contract 54763

air temperature 14 °C louvre height 1015 mm
 barometer 1007 mbar louvre width 1000 mm
 air density 1.217 kg/m³ louvre area 1.015 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient Cd
	m/s	test m ³ /s	theoretical m ³ /s	
214.0	3.72	3.778	19.036	0.198
195.0	3.55	3.599	18.171	0.198
171.0	3.34	3.386	17.016	0.199
149.0	3.12	3.167	15.884	0.199
127.0	2.88	2.918	14.665	0.199
106.5	2.63	2.665	13.429	0.198
85.0	2.35	2.384	11.997	0.199
65.4	2.07	2.096	10.523	0.199
44.1	1.70	1.722	8.641	0.199
24.0	1.26	1.282	6.375	0.201
mean Cd				0.199
Class				4



CLASSIFICATION OF WEATHER LOUVRES

Weather louvres shall be classified by their ability to reject simulated rain.

Penetration Classification

Table 1 shows the different classifications based on the maximum simulated rain penetration per square metre of louvre. The classification is determined in accordance with section 8.2 of EN 13030:2001.

Water penetration rating at a given louvre face velocity is determined by the water penetration while the louvre is subjected to a 13 ms^{-1} simulated wind velocity and a simulated rain fall at the nominal rate.

Table 1 Penetration classification

Class	Effectiveness	Maximum allowed penetration of simulated rain $\text{l.h}^{-1}.\text{m}^{-2}$
A	1,00 TO 0,99	0,75
B	0,989 TO 0,95	3,75
C	0,949 TO 0,80	15,0
D	Below 0,8	Greater than 15,0

These classifications apply to various core velocities.

Discharge and Entry Loss Coefficient

The discharge and entry loss coefficient given in Table 2, shall be determined in accordance with section 8.3 of test standard EN13030:2001.

Table 2 Discharge and Entry loss coefficient classification

Class	Discharge and Entry Loss Coefficient
1	0,4 and above
2	0,3 to 0,399
3	0,2 to 0,299
4	0,199 and below