

Summary Report

www.bsria.co.uk

Summary Report 54763/2

Issue No: 1

Date of issue: 9 October 2018

This Summary Report confirms that BSRIA Ltd has tested a sample of the product described below in accordance with the test methods contained within EN 13030:2001 and have determined the item met the detailed classification shown on pages 3 to 6. For further details of the test item see Page 2 of this Summary Report.

Manufacturer/Agent	N.V. Renson Projects IZ 2 Vijverdam Maalbeekstraat 6 B-8790 Waregem
Product	421 WK2
Test location	BSRIA Old Bracknell West Bracknell Berkshire RG12 7AH
Date of test	22 December 2010 and 11 February 2011
Date of issue	9 October 2018
Test engineer	A Freeth
Quality approved	Mark Roper Principal Test Engineer

This Summary Report must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

This summary report supersedes certificate 54763/2. This up-date was carried out under BSRIA contract reference 61223.

TEST INFORMATION

Contract	54763
Date	December 2010
Manufacturer	N.V. Renson Projects
Louvre Model	421 WK2
Material	Aluminium
Painted	No
Blade Height	1025 mm
Blade Width	1000 mm
Blade Depth	42 mm
Frame Depth	48 mm
No. of Blades	20
Blade Pitch	50 mm
Blade Angle	45 degrees
No. of Banks	1
Guard Type	Insect/None
Guard Spacing	8 mm
Side Channels	None
Water Drip Tray	Yes
Blade Orientation	Horizontal

Front view of louvre


COEFFICIENT OF ENTRY (with mesh)

MANUFACTURER Renson
 MODEL 421 WK2 (with mesh)

Date 22/12/2010
 Contract 54763

air temperature 11.5 °C louvre height 1025 mm
 barometer 1003 mbar louvre width 1000 mm
 air density 1.223 kg/m³ louvre area 1.025 m²

louvre pd Pascals	louvre face velocity		air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s		
130.0	3.87	3.970	14.947	0.266	
116.0	3.69	3.778	14.119	0.268	
101.0	3.44	3.527	13.175	0.268	
88.0	3.20	3.278	12.298	0.267	
71.0	2.87	2.944	11.046	0.267	
54.0	2.52	2.585	9.634	0.268	
36.0	2.13	2.184	7.866	0.278	
25.0	1.72	1.759	6.555	0.268	
10.4	1.13	1.162	4.228	0.275	
mean C _e				0.269	
Class				3	




COEFFICIENT OF DISCHARGE (with mesh)

MANUFACTURER Renson Date 22/12/2010
 MODEL 421 WK2 Reversed (with mesh) Contract 54763

air temperature 11.5 °C louvre height 1025 mm
 barometer 1003 mbar louvre width 1000 mm
 air density 1.223 kg/m³ louvre area 1.025 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient Cd
	m/s	test m ³ /s	theoretical m ³ /s	
119.0	3.84	3.939	14.301	0.275
109.0	3.69	3.785	13.687	0.277
94.0	3.44	3.530	12.710	0.278
82.0	3.22	3.296	11.871	0.278
65.0	2.86	2.932	10.569	0.277
50.0	2.53	2.595	9.270	0.280
37.0	2.15	2.200	7.974	0.276
23.0	1.72	1.759	6.287	0.280
8.8	1.11	1.142	3.889	0.294
mean Cd				0.279
Class				3




COEFFICIENT OF ENTRY (no mesh)

MANUFACTURER Renson Date 11/02/2011
 MODEL 421 WK2 (no mesh) Contract 54763

air temperature 11.5 °C louvre height 1025 mm
 barometer 1007 mbar louvre width 1000 mm
 air density 1.228 kg/m³ louvre area 1.025 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s	
118.0	3.84	3.931	14.212	0.277
108.0	3.65	3.742	13.597	0.275
95.0	3.45	3.533	12.752	0.277
84.5	3.25	3.329	12.027	0.277
75.0	3.06	3.134	11.331	0.277
64.5	2.84	2.910	10.508	0.277
53.4	2.59	2.658	9.561	0.278
42.0	2.30	2.355	8.479	0.278
32.1	2.02	2.067	7.413	0.279
8.4	1.06	1.086	3.792	0.286
mean C _e				0.278
Class				3




COEFFICIENT OF DISCHARGE (no mesh)

MANUFACTURER Renson Date 22/12/2010
 MODEL 421 WK2 Reversed (no mesh) Contract 54763

air temperature 11.5 °C louvre height 1025 mm
 barometer 1007 mbar louvre width 1000 mm
 air density 1.228 kg/m³ louvre area 1.025 m²

louvre pd Pascals	louvre face velocity		air flow rate		coefficient Cd
	m/s	test m ³ /s	theoretical m ³ /s		
108.0	3.82	3.919	13.597	0.288	
98.5	3.62	3.707	12.985	0.286	
86.5	3.40	3.489	12.168	0.287	
75.4	3.16	3.235	11.361	0.285	
65.0	2.94	3.018	10.548	0.286	
54.0	2.69	2.754	9.614	0.286	
41.5	2.35	2.413	8.428	0.286	
31.3	2.03	2.078	7.320	0.284	
20.5	1.65	1.690	5.924	0.285	
9.4	1.13	1.160	4.011	0.289	
mean Cd				0.286	
Class				3	



CLASSIFICATION OF WEATHER LOUVRES

Weather louvres shall be classified by their ability to reject simulated rain.

Penetration Classification

Table 1 shows the different classifications based on the maximum simulated rain penetration per square metre of louvre. The classification is determined in accordance with section 8.2 of EN 13030:2001.

Water penetration rating at a given louvre face velocity is determined by the water penetration while the louvre is subjected to a 13 ms^{-1} simulated wind velocity and a simulated rain fall at the nominal rate.

Table 1 Penetration classification

Class	Effectiveness	Maximum allowed penetration of simulated rain $\text{l.h}^{-1}.\text{m}^{-2}$
A	1,00 TO 0,99	0,75
B	0,989 TO 0,95	3,75
C	0,949 TO 0,80	15,0
D	Below 0,8	Greater than 15,0

These classifications apply to various core velocities.

Discharge and Entry Loss Coefficient

The discharge and entry loss coefficient given in Table 2, shall be determined in accordance with section 8.3 of test standard EN13030:2001.

Table 2 Discharge and Entry loss coefficient classification

Class	Discharge and Entry Loss Coefficient
1	0,4 and above
2	0,3 to 0,399
3	0,2 to 0,299
4	0,199 and below