

Summary Report

www.bsria.co.uk

Summary Report 54763/3

Issue No: 1

Date of issue: 10 October 2018

This Summary Report confirms that BSRIA Ltd has tested a sample of the product described below in accordance with the test methods contained within EN 13030 : 2001 and have determined the item met the detailed classification shown on pages 3 to 6. For further details of the test item see Page 2 of this Summary Report.

Manufacturer/Agent	N.V. Renson Projects IZ 2 Vijverdam Maalbeekstraat 6 B-8790 Waregem
Product	L.060HF
Test location	BSRIA Old Bracknell West Bracknell Berkshire RG12 7AH
Date of test	10 February 2011
Date of issue	9 October 2018
Test engineer	A Freeth
Quality approved	Mark Roper Principal Test Engineer


This Summary Report must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

This summary report supersedes certificate 54763/3. This up-date was carried out under BSRIA contract reference 61223.

TEST INFORMATION

Contract	54763
Date	February 2011
Manufacturer	N.V. Renson Projects
Louvre Model	L.060HF
Material	Aluminium
Painted	No
Blade Height	1035 mm
Blade Width	1000 mm
Blade Depth	78 mm
Frame Depth	83 mm
No. of Blades	17
Blade Pitch	60 mm
Blade Angle	45 degrees
No. of Banks	1
Guard Type	Insect/None
Guard Spacing	7 mm
Side Channels	None
Water Drip Tray	Yes
Blade Orientation	Horizontal

Front view of louvre




COEFFICIENT OF ENTRY (with mesh)

MANUFACTURER Renson
 MODEL L.060 HF (2.3mm mesh)

Date 10/02/2011
 Contract 54763

air temperature 13 °C louvre height 1035 mm
 barometer 1009 mbar louvre width 1000 mm
 air density 1.224 kg/m³ louvre area 1.035 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s	
55.5	4.02	4.159	9.858	0.422
50.0	3.79	3.927	9.357	0.420
43.6	3.58	3.703	8.738	0.424
38.0	3.35	3.464	8.157	0.425
33.5	3.13	3.236	7.659	0.422
27.2	2.81	2.911	6.901	0.422
21.5	2.49	2.581	6.136	0.421
15.7	2.14	2.213	5.243	0.422
10.0	1.71	1.766	4.185	0.422
5.3	1.26	1.304	3.046	0.428
mean C _e				0.423
Class				1




COEFFICIENT OF DISCHARGE (with mesh)

MANUFACTURER Renson Date 10/02/2011
 MODEL L.060 HF Reversed (2.3mm mesh) Contract 54763

air temperature 13 °C louvre height 1035 mm
 barometer 1009 mbar louvre width 1000 mm
 air density 1.224 kg/m³ louvre area 1.035 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient Cd
	m/s	test m ³ /s	theoretical m ³ /s	
56.5	4.03	4.170	9.947	0.419
51.5	3.82	3.955	9.496	0.416
45.3	3.59	3.711	8.906	0.417
39.3	3.36	3.473	8.296	0.419
34.3	3.14	3.245	7.750	0.419
27.7	2.82	2.922	6.965	0.420
21.7	2.51	2.593	6.164	0.421
15.7	2.13	2.209	5.243	0.421
9.7	1.72	1.779	4.121	0.432
5.0	1.25	1.294	2.959	0.437
mean Cd				0.422
Class				1




COEFFICIENT OF ENTRY (no mesh)

MANUFACTURER Renson
 MODEL L.060 HF (no mesh)

Date 10/02/2011
 Contract 54763

air temperature 13 °C louvre height 1035 mm
 barometer 1009 mbar louvre width 1000 mm
 air density 1.224 kg/m³ louvre area 1.035 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s	
50.0	4.02	4.159	9.357	0.444
46.0	3.83	3.967	8.975	0.442
40.0	3.60	3.728	8.369	0.445
35.0	3.33	3.446	7.829	0.440
29.1	3.06	3.168	7.138	0.444
23.5	2.76	2.857	6.415	0.445
18.3	2.46	2.550	5.661	0.451
13.4	2.09	2.159	4.844	0.446
9.2	1.74	1.805	4.014	0.450
4.4	1.22	1.258	2.776	0.453
mean C _e				0.446
Class				1




COEFFICIENT OF DISCHARGE (no mesh)

MANUFACTURER Renson Date 10/02/2011
 MODEL L.060 HF Reversed (no mesh) Contract 54763

air temperature 13 °C louvre height 1035 mm
 barometer 1009 mbar louvre width 1000 mm
 air density 1.224 kg/m³ louvre area 1.035 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient Cd
	m/s	test m ³ /s	theoretical m ³ /s	
52.6	4.05	4.196	9.597	0.437
47.0	3.83	3.967	9.072	0.437
41.0	3.59	3.711	8.473	0.438
35.8	3.36	3.477	7.918	0.439
31.1	3.14	3.250	7.380	0.440
25.5	2.84	2.938	6.682	0.440
19.0	2.49	2.581	5.768	0.447
14.1	2.15	2.230	4.969	0.449
8.2	1.70	1.761	3.789	0.465
3.5	1.20	1.243	2.476	0.502
mean Cd				0.449
Class				1



CLASSIFICATION OF WEATHER LOUVRES

Weather louvres shall be classified by their ability to reject simulated rain.

Penetration Classification

Table 1 shows the different classifications based on the maximum simulated rain penetration per square metre of louvre. The classification is determined in accordance with section 8.2 of EN 13030:2001.

Water penetration rating at a given louvre face velocity is determined by the water penetration while the louvre is subjected to a 13 ms^{-1} simulated wind velocity and a simulated rain fall at the nominal rate.

Table 1 Penetration classification

Class	Effectiveness	Maximum allowed penetration of simulated rain $\text{l.h}^{-1}.\text{m}^{-2}$
A	1,00 TO 0,99	0,75
B	0,989 TO 0,95	3,75
C	0,949 TO 0,80	15,0
D	Below 0,8	Greater than 15,0

These classifications apply to various core velocities.

Discharge and Entry Loss Coefficient

The discharge and entry loss coefficient given in Table 2, shall be determined in accordance with section 8.3 of test standard EN13030:2001.

Table 2 Discharge and Entry loss coefficient classification

Class	Discharge and Entry Loss Coefficient
1	0,4 and above
2	0,3 to 0,399
3	0,2 to 0,299
4	0,199 and below